Sliptest Australia Pty Ltd
NATA Accreditation No: 15374
11 Fuchsia Way Gaven QLD 4211, Gaven, QLD, 4211
kathryn@sliptest.com.au
www.sliptest.com.au
1300 754 783

## Modinex Group - VIROC RAW GREY - Wet Sliptest BO230123-4 — 23 Jan 2023

# Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

| | |
|---|---|
| Date Tested: | 23 Jan 2023 |
| Test Report Number: | BO230123-4 |
| Client Name & Billing Address: | Modinex Group - Springfield Tower, Level 7/145 Sinnathamby Blvd Springfield Central QLD 4300 |
| Surface Tested : (Samples and Test Information Supplied by Client) | 30x30cm VIROC RAW GREY Sample |
| Wet Pendulum Test carried out using : | Slider 96 (4S) Rubber slider |
| Testing Officer / Approved Signatory: | Blair Ording |
| Pendulum in use - Calibration Date : | #SK2072 - Wessex Portable Skid Tester (C : 07.05.21) |
| Signature of Approved Signatory : |  |

**Test Results :**

| Sample No. | Swing 1 | Swing 2 | Swing 3 | Swing 4 | Swing 5 | Mean BPN of last 3 swings : | SCV : | Surface Picture |
|---|---|---|---|---|---|---|---|---|
| Sample 1 | 60 | 57 | 56 | 56 | 56 | 56 | N/A | |
| Sample 2 | 62 | 61 | 60 | 60 | 60 | 60 | N/A | |
| Sample 3 | 62 | 62 | 60 | 60 | 60 | 60 | N/A | |
| Sample 4 | 62 | 61 | 60 | 60 | 60 | 60 | N/A | |
| Sample 5 | 63 | 62 | 61 | 61 | 61 | 61 | N/A |  |

| | |
|---|---|
| Reported SRV For Test Area : | 59 |
| CLASSIFICATION using Slider 96 (4S Slider) | P5 = > 54 |

*Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results to not account for Future Wear, Maintenance or Contamination of this surface once in-situ.*



Submitted by: Blair Ording @ 11:29:26 23 Jan 2023
Submission ID: 11848508
Environment friendly, paperless solution by www.formitize.com

Issue: Controlled Document ID: 23422 - 1 Version: 148
PAGE TEST FORM (AS4586 ONLY)

Submitted by: Blair Ording @ 11:29:26 23 Jan 2023
Submission ID: 11848508
Environment friendly, paperless solution by www.formitize.com

Issue: Controlled Document ID: 23422 - 1 Version: 148
PAGE TEST FORM (AS4586 ONLY)